

## Declaration of conformity

### No.121a/EN

<b>Manufacturer</b>	<b>KLIMAOPREMA d.d.</b> Gradna 78A, 10430 Samobor, Croatia
<b>Person authorized to compile technical documentation</b>	Siniša Murtezanović, <i>mag.eng.mech.</i> <i>Chief technical officer</i>
<b>Product description</b>	General product name: <b>plenum box</b> Product type: <b>plenum box for ventilation grilles</b> Product model: <b>PK1, PK2, PK3</b> Product use: <b>air distribution element in ventilation systems</b>

We declare under our own responsibility that described products meets the characteristics and properties and is in accordance with the data described in the technical documentation. Technical documentation for the listed product is available on our website: [www.klimaoprema.com](http://www.klimaoprema.com).

We declare under our own responsibility that the described product meets the requirements of the following standards:

EN 13182:2002	Ventilation for buildings -- Instrumentation requirements for air velocity measurements in ventilated spaces
EN 14277:2006	Ventilation for buildings. Air terminal devices. Method for airflow measurement by calibrated sensors in or close to ATD/plenum boxes
EN 15727:2010	Ventilation for buildings – Duct and ductwork components, leakage classification and testing

#### Reaction to fire, resistance to fire:

Product is made of galvanized steel sheet and it is considered to be reaction to fire Class A1, in accordance with Commission Decision 1996/603/EC and Commission Decision 2000/605/EC.

#### Emissions of dangerous substances:

Product does not contain harmful substances to human and environmental.

The product is produced and controlled in accordance with an integrated management system that includes the following standards:

ISO 9001:2015	TÜV NORD no. 44 100 20430031
ISO 14001:2015	TÜV NORD no. 44 104 20430031
ISO 45001:2018	TÜV NORD no. 44 126 20430031


Technical documentation reference number: **TM 121a.**

EU Declaration of conformity according to the valid EU Directives is not allowed because there are no harmonised standards for the product.

Signed for the manufacturer on his behalf:

Sergio Galošić, CEO

2 klimaoprema d.d.  
Za projektiranje, proizvodnju, postavljanje,  
popravak i održavanje opreme za klimatizaciju  
10430 SAMOBOR, GRADNA 78/A



Samobor, 17.03.2020.