

Declaration of conformity

No.1237/EN

| | |
|---|---|
| Manufacturer | KLIMAOPREMA d.d. Gradna 78A, 10430 Samobor, Croatia |
| Person authorized to compile technical documentation | Siniša Murtezanović, <i>mag.eng.mech.</i> Chief technical officer |
| Product description | General product name: air terminal device Product type: ceiling diffuser Product model: ODP Product use: air distribution element in ventilation systems |

We declare under our own responsibility that described products meets the characteristics and properties and is in accordance with the data described in the technical documentation. Technical documentation for the listed product is available on our website: www.klimaoprema.com.

We hereby declare that the described product meets the requirements of the following standards:

| | |
|---------------|---|
| EN 13182:2002 | Ventilation for buildings -- Instrumentation requirements for air velocity measurements in ventilated spaces |
| EN 12238:2004 | Ventilation for buildings -- Air terminal devices. Aerodynamic testing and rating for mixed flow application |
| EN 12239:2001 | Ventilation for buildings -- Air terminal devices -- Aerodynamic testing and rating for displacement flow applications |
| EN 14277:2006 | Ventilation for buildings. Air terminal devices. Method for airflow measurement by calibrated sensors in or close to ATD/plenum boxes |

Reaction to fire, resistance to fire:

Product is made of galvanized steel sheet, powder coated (coating < 1,0 mm) and is considered to be reaction to fire Class A1, in accordance with Commission Decision 1996/603/EC and Commission Decision 2000/605/EC.

Emissions of dangerous substances:

Product does not contain harmful substances to human and environment.

The product is produced and controlled in accordance with an integrated management system that includes the following standards:

| | |
|----------------|------------------------------|
| ISO 9001:2015 | TÜV NORD no. 44 100 20430031 |
| ISO 14001:2015 | TÜV NORD no. 44 104 20430031 |
| ISO 45001:2018 | TÜV NORD no. 44 126 20430031 |


Technical documentation reference number: **TM 1237.**

EU Declaration of conformity according to the valid EU Directives is not allowed because there are no harmonised standards for the product.

Signed for the manufacturer on his behalf:

Sergio Galošić, CEO

klimaoprema d.d.
Za projektiranje, proizvodnju, postavljanje,
popravak i održavanje opreme za klimatizaciju
10430 SAMOBOR, GRADNA 78/A



Samobor, 17.03.2020.